



CITY AND BOROUGH OF SITKA

Legislation Text

File #: RES 17-02, **Version:** 1

In support of the State of Alaska adopting the following fine print note to the 2017 National Electrical Code Article 555.3: "FPN: the 30MA requirement can be applied to all feeder circuits or all branch circuits in lieu of the main overcurrent protection device."