



CITY AND BOROUGH OF SITKA

Legislation Details

File #: RES 17-02 **Version:** 1 **Name:**
Type: Resolution **Status:** PASSED
File created: 1/17/2017 **In control:** City and Borough Assembly
On agenda: 1/24/2017 **Final action:** 1/24/2017
Title: In support of the State of Alaska adopting the following fine print note to the 2017 National Electrical Code Article 555.3: "FPN: the 30MA requirement can be applied to all feeder circuits or all branch circuits in lieu of the main overcurrent protection device."

Sponsors:

Indexes:

Code sections:

Attachments: 1. Res 2017-02.pdf, 2. RES 2017-02 Signed.pdf

Date	Ver.	Action By	Action	Result
1/24/2017	1	City and Borough Assembly	APPROVED	